



हिंदुस्तान ऑर्गेनिक केमिकल्स लिमिटेड
HINDUSTAN ORGANIC CHEMICALS LTD
(भारत सरकार का उद्यम, A Government of India Enterprise)
अंबलमुगल, कोची AMBALAMUGAL, COCHIN – 682 302
दूरभाष Phone: (0484) 2727464, 454, ईमेल E-mail: kochi@hoclindia.com

MAT/PUR/22461/24

08.10.2024

SPECIFICATION SHEET

<u>SL. No.</u>	<u>ITEM DESCRIPTION</u>	<u>QTY UNIT</u>
1	Type: ML4 Power Contactor L&T make, Cat No. SS90910 Conformance Standards: IS/IEC 60947-4-1, IEC 60947-4-1 No. of poles: 3 Poles Motor duty 3Ø, 415V, 50 Hz Utilization category AC-3: 37/70 (kW/A) Coil Supply: 110V AC Auxiliary Contacts: 2 NO + 2 NC	4.0000 NOS
2	Type: ML3 Power Contactor L&T make, Cat No. SS90721 Conformance Standards: IS/IEC 60947-4-1, IEC 60947-4-1 No. of poles: 3 Poles Motor duty 3Ø, 415V, 50 Hz Utilization category AC-3: 22/40 (kW/A) Coil Supply: 110V AC Auxiliary Contacts: 2 NO + 2 NC	4.0000 NOS
3	Type: ML1.5 Power Contactor L&T make, Cat No. SS91851 Conformance Standards: IS/IEC 60947-4-1, IEC 60947-4-1 No. of poles: 3 Poles Motor duty 3Ø, 415V, 50 Hz Utilization category AC-3: 11 / 25 (kW/A) Coil Supply: 110V AC Auxiliary Contacts: 2 NO + 2 NC	4.0000 NOS
4	Type: MN5 Thermal Overload Relay L&T make, Cat No. SS94136OOGO Conformance Standards: IS/IEC 60947-4-1 & IEC 60947-4-1 No. of poles: 3 Poles Current range: 30 – 50 A Mounting: Direct Suitable for contactors: MNX 50, 70, 80 Start / OFF / Reset: 1 Start & OFF / Reset	5.0000 NOS

5	Type: MN5 Thermal Overload Relay L&T make, Cat No. SS94135O0BO Conformance Standards: IS/IEC 60947-4-1 & IEC 60947-4-1 No. of poles: 3 Poles Current range: 9-15 A Mounting: Direct Suitable for contactors: MNX 50, 70, 80 Start / OFF / Reset: 1 Start & OFF / Reset	5.0000 NOS
6	Type: MN2 Thermal Overload Relay L&T make, Cat No. SS94142O0BO Conformance Standards: IS/IEC 60947-4-1 & IEC 60947-4-1 No. of poles: 3 Poles Current range: 9-15 A Mounting: Direct Suitable for contactors: MNX 9-40 Start / OFF / Reset: 1 Start & OFF / Reset	5.0000 NOS
7	High brightness and uniform LED Indication Lamp, Red colour Supply Voltage: 110VAC Bezel size:22.5 mm Type of LEDs: SMD LEDs Colour: Red Operating frequency:50 Hz Operating temperature: up to 65 degC Wire termination capacity: 2.5 sq.mm, 2 nos Operating life: 1,00,000 hours Low voltage glow protection: Yes Ingress protection: IP65 for front and IP20 for rear terminals. L&T make, Cat No. EPLR110A	50.0000 NOS
8	High brightness and uniform LED Indication Lamp, Green colour,22.5 mm dia. Supply Voltage: 110VAC Bezel size:22.5 mm Type of LEDs: SMD LEDs Colour: Green Operating frequency:50 Hz Operating temperature: up to 65 degC Wire termination capacity: 2.5 sq.mm, 2 nos Operating life: 1,00,000 hours Low voltage glow protection: Yes Ingress protection: IP65 for front and IP20 for rear terminals. L&T make, Cat No. EPLG110A	50.0000 NOS

9	<p>High brightness and uniform LED Indication Lamp, Amber colour, 22.5 mm dia. Supply Voltage: 110VAC Bezel size:22.5 mm Type of LEDs: SMD LEDs Colour: Amber Operating frequency:50 Hz Operating temperature: up to 65 degC Wire termination capacity: 2.5 sq.mm, 2 nos Operating life: 1,00,000 hours Low voltage glow protection: Yes Ingress protection: IP65 for front and IP20 for rear terminals. L&T make, Cat No. EPLA110A</p>	50.0000 NOS
10	<p>High brightness and uniform LED Indication Lamp, Red colour Supply Voltage: 110VDC Bezel size:22.5 mm Type of LEDs: SMD LEDs Colour: Red Operating frequency:50 Hz Operating temperature: up to 65 degC Wire termination capacity: 2.5 sq.mm, 2 nos Operating life: 1,00,000 hours Low voltage glow protection: Yes Ingress protection: IP65 for front and IP20 for rear terminals. L&T make, Cat No. EPLR110D</p>	30.0000 NOS
11	<p>High brightness and uniform LED Indication Lamp, Green colour,22.5 mm dia. Supply Voltage: 110VDC Bezel size:22.5 mm Type of LEDs: SMD LEDs Colour: Green Operating frequency:50 Hz Operating temperature: up to 65 degC Wire termination capacity: 2.5 sq.mm, 2 nos Operating life: 1,00,000 hours Low voltage glow protection: Yes Ingress protection: IP65 for front and IP20 for rear terminals. L&T make, Cat No. EPLG110D</p>	30.0000 NOS

12	High brightness and uniform LED Indication Lamp, Amber colour,22.5 mm dia. Supply Voltage: 110VDC Bezel size:22.5 mm Type of LEDs: SMD LEDs Colour: Amber Operating frequency:50 Hz Operating temperature: up to 65 degC Wire termination capacity: 2.5 sq.mm, 2 nos Operating life: 1,00,000 hours Low voltage glow protection: Yes Ingress protection: IP65 for front and IP20 for rear terminals. L&T make, Cat No. EPLA110D	30.0000 NOS
13	High brightness and uniform LED Indication Lamp, Blue colour Supply Voltage: 110VDC Bezel size:22.5 mm Type of LEDs: SMD LEDs Colour: Blue Operating frequency:50 Hz Operating temperature: up to 65 degC Wire termination capacity: 2.5 sq.mm, 2 nos Operating life: 1,00,000 hours Low voltage glow protection: Yes Ingress protection: IP65 for front and IP20 for rear terminals. L&T make, Cat No. EPLB110D	30.0000 NOS
14	High brightness and uniform LED Indication Lamp, White colour Supply Voltage: 110VDC Bezel size:22.5 mm Type of LEDs: SMD LEDs Colour: White Operating frequency:50 Hz Operating temperature: up to 65 degC Wire termination capacity: 2.5 sq.mm, 2 nos Operating life: 1,00,000 hours Low voltage glow protection: Yes Ingress protection: IP65 for front and IP20 for rear terminals. L&T make, Cat No. EPLW110D	30.0000 NOS
15	Kit for Mounting MN 5 Relay on ML 4 / ML 6 contactor L&T make, Cat No. SS941520000	10.0000 NOS
16	HRC Fuse base with carrier Type: HC, 63A, 415V L&T make, Category no: SK91043 (both side cable) Suitable for L&T HF type Cylindrical fuse 2-63A	30.0000 NOS

17	<p>Type: ML4 Power Contactor L&T make, Cat No. SS90910 Conformance Standards: IS/IEC 60947-4-1, IEC 60947-4-1 No. of poles: 3 Poles Motor duty 3Ø, 415V, 50 Hz Utilization category AC-3: 37/70 (kW/A) Coil Supply: 240V AC Auxiliary Contacts: 2 NO + 2 NC</p>	8.0000 NOS
18	<p>High brightness and uniform LED Indication Lamp, Red colour Supply Voltage: 415VAC Bezel size:22.5 mm Type of LEDs: SMD LEDs Colour: Red Operating frequency:50 Hz Operating temperature: up to 65 degC Wire termination capacity: 2.5 sq.mm, 2 nos Operating life: 1,00,000 hours Low voltage glow protection: Yes Ingress protection: IP65 for front and IP20 for rear terminals. L&T make, Cat No. EPLR415A</p>	10.0000 NOS
19	<p>High brightness and uniform LED Indication Lamp, Yellow colour Supply Voltage: 415VAC Bezel size:22.5 mm Type of LEDs: SMD LEDs Colour: Red Operating frequency:50 Hz Operating temperature: up to 65 degC Wire termination capacity: 2.5 sq.mm, 2 nos Operating life: 1,00,000 hours Low voltage glow protection: Yes Ingress protection: IP65 for front and IP20 for rear terminals. L&T make, Cat No. EPLY415A</p>	10.0000 NOS
20	<p>High brightness and uniform LED Indication Lamp, Blue colour Supply Voltage: 415VAC Bezel size:22.5 mm Type of LEDs: SMD LEDs Colour: Red Operating frequency:50 Hz Operating temperature: up to 65 degC Wire termination capacity: 2.5 sq.mm, 2 nos Operating life: 1,00,000 hours Low voltage glow protection: Yes Ingress protection: IP65 for front and IP20 for rear terminals. L&T make, Cat No. EPLB415A</p>	10.0000 NOS

NOTE:

1. MAKE: L&T ELECTRICAL AND AUTOMATION
2. PRODUCT CATALOG SHALL BE PROVIDED ALONG WITH THE BID DOCUMENT.
3. TEST CERTIFICATES TO BE PROVIDED ALONG WITH THE SUPPLY.
4. THE SPECIFICATION SHEET / CATALOGUE OF OFFERED ITEMS SHOULD BE SIGNED AND SUBMITTED ALONG WITH THE OFFER. IF ANY DEVIATIONS YOU SHOULD MENTION IT CLEARLY.





हिंदुस्तान ऑर्गेनिक केमिकल्स लिमिटेड
HINDUSTAN ORGANIC CHEMICALS LTD
(भारत सरकार का उद्यम, A Government of India Enterprise)
अंबलमुगल, कोची AMBALAMUGAL, COCHIN – 682 302
दूरभाष Phone: (0484) 2720911, ईमेल E-mail: kochi@hoclindia.com

MAT/PUR/22461/24

08.10.2024

M/s.

Dear Sir,

Hindustan Organic Chemicals Ltd. is a Govt. of India Undertaking manufacturing Phenol, Acetone & Hydrogen Peroxide at its plant at Kochi, Kerala, India.

HOCL invites e-tenders: **POWER CONTACTORS, THERMAL OVERLOAD RELAY, INDICATION LAMP AND HRC FUSE BASE & HOLDER.**

You may submit your offer on single bid system online before the due date and time specified.

Thanking you,

Yours faithfully,
For Hindustan Organic Chemicals Ltd.

B. Balachandran
General Manager (Materials/MSS)

SPECIFICATION SHEET

<u>SL.No.</u>	<u>ITEM DESCRIPTION</u>	<u>QTY</u>
1	Type: ML4 Power Contactor L&T make, Cat No. SS90910 Conformance Standards: IS/IEC 60947-4-1, IEC 60947-4-1 No. of poles: 3 Poles Motor duty 3Ø, 415V, 50 Hz Utilization category AC-3: 37/70 (kW/A) Coil Supply: 110V AC Auxiliary Contacts: 2 NO + 2 NC	4.0000 NOS
2	Type: ML3 Power Contactor L&T make, Cat No. SS90721 Conformance Standards: IS/IEC 60947-4-1, IEC 60947-4-1 No. of poles: 3 Poles Motor duty 3Ø, 415V, 50 Hz Utilization category AC-3: 22/40 (kW/A) Coil Supply: 110V AC Auxiliary Contacts: 2 NO + 2 NC	4.0000 NOS
3	Type: ML1.5 Power Contactor L&T make, Cat No. SS91851 Conformance Standards: IS/IEC 60947-4-1, IEC 60947-4-1 No. of poles: 3 Poles Motor duty 3Ø, 415V, 50 Hz Utilization category AC-3: 11 / 25 (kW/A) Coil Supply: 110V AC Auxiliary Contacts: 2 NO + 2 NC	4.0000 NOS
4	Type: MN5 Thermal Overload Relay L&T make, Cat No. SS94136OOGO Conformance Standards: IS/IEC 60947-4-1 & IEC 60947-4-1 No. of poles: 3 Poles Current range: 30 – 50 A Mounting: Direct Suitable for contactors: MNX 50, 70, 80 Start / OFF / Reset: 1 Start & OFF / Reset	5.0000 NOS
5	Type: MN5 Thermal Overload Relay L&T make, Cat No. SS94135OOBO Conformance Standards: IS/IEC 60947-4-1 & IEC 60947-4-1 No. of poles: 3 Poles Current range: 9-15 A Mounting: Direct Suitable for contactors: MNX 50, 70, 80 Start / OFF / Reset: 1 Start & OFF / Reset	5.0000 NOS

SL.No.	ITEM DESCRIPTION	QTY
6	Type: MN2 Thermal Overload Relay L&T make, Cat No. SS94142O0BO Conformance Standards: IS/IEC 60947-4-1 & IEC 60947-4-1 No. of poles: 3 Poles Current range: 9-15 A Mounting: Direct Suitable for contactors: MNX 9-40 Start / OFF / Reset: 1 Start & OFF / Reset	5.0000 NOS
7	High brightness and uniform LED Indication Lamp, Red colour Supply Voltage: 110VAC Bezel size:22.5 mm Type of LEDs: SMD LEDs Colour: Red Operating frequency:50 Hz Operating temperature: up to 65 degC Wire termination capacity: 2.5 sq.mm, 2 nos Operating life: 1,00,000 hours Low voltage glow protection: Yes Ingress protection: IP65 for front and IP20 for rear terminals. L&T make, Cat No. EPLR110A	50.0000 NOS
8	High brightness and uniform LED Indication Lamp, Green colour,22.5 mm dia. Supply Voltage: 110VAC Bezel size:22.5 mm Type of LEDs: SMD LEDs Colour: Green Operating frequency:50 Hz Operating temperature: up to 65 degC Wire termination capacity: 2.5 sq.mm, 2 nos Operating life: 1,00,000 hours Low voltage glow protection: Yes Ingress protection: IP65 for front and IP20 for rear terminals. L&T make, Cat No. EPLG110A	50.0000 NOS
9	High brightness and uniform LED Indication Lamp, Amber colour,22.5 mm dia. Supply Voltage: 110VAC Bezel size:22.5 mm Type of LEDs: SMD LEDs Colour: Amber Operating frequency:50 Hz Operating temperature: up to 65 degC Wire termination capacity: 2.5 sq.mm, 2 nos Operating life: 1,00,000 hours Low voltage glow protection: Yes Ingress protection: IP65 for front and IP20 for rear terminals. L&T make, Cat No. EPLA110A	50.0000 NOS

SL.No.	ITEM DESCRIPTION	QTY
10	High brightness and uniform LED Indication Lamp, Red colour Supply Voltage: 110VDC Bezel size:22.5 mm Type of LEDs: SMD LEDs Colour: Red Operating frequency:50 Hz Operating temperature: up to 65 degC Wire termination capacity: 2.5 sq.mm, 2 nos Operating life: 1,00,000 hours Low voltage glow protection: Yes Ingress protection: IP65 for front and IP20 for rear terminals. L&T make, Cat No. EPLR110D	30.0000 NOS
11	High brightness and uniform LED Indication Lamp, Green colour,22.5 mm dia. Supply Voltage: 110VDC Bezel size:22.5 mm Type of LEDs: SMD LEDs Colour: Green Operating frequency:50 Hz Operating temperature: up to 65 degC Wire termination capacity: 2.5 sq.mm, 2 nos Operating life: 1,00,000 hours Low voltage glow protection: Yes Ingress protection: IP65 for front and IP20 for rear terminals. L&T make, Cat No. EPLG110D	30.0000 NOS
12	High brightness and uniform LED Indication Lamp, Amber colour,22.5 mm dia. Supply Voltage: 110VDC Bezel size:22.5 mm Type of LEDs: SMD LEDs Colour: Amber Operating frequency:50 Hz Operating temperature: up to 65 degC Wire termination capacity: 2.5 sq.mm, 2 nos Operating life: 1,00,000 hours Low voltage glow protection: Yes Ingress protection: IP65 for front and IP20 for rear terminals. L&T make, Cat No. EPLA110D	30.0000 NOS

SL.No.	ITEM DESCRIPTION	QTY
13	High brightness and uniform LED Indication Lamp, Blue colour Supply Voltage: 110VDC Bezel size:22.5 mm Type of LEDs: SMD LEDs Colour: Blue Operating frequency:50 Hz Operating temperature: up to 65 degC Wire termination capacity: 2.5 sq.mm, 2 nos Operating life: 1,00,000 hours Low voltage glow protection: Yes Ingress protection: IP65 for front and IP20 for rear terminals. L&T make, Cat No. EPLB110D	30.0000 NOS
14	High brightness and uniform LED Indication Lamp, White colour Supply Voltage: 110VDC Bezel size:22.5 mm Type of LEDs: SMD LEDs Colour: White Operating frequency:50 Hz Operating temperature: up to 65 degC Wire termination capacity: 2.5 sq.mm, 2 nos Operating life: 1,00,000 hours Low voltage glow protection: Yes Ingress protection: IP65 for front and IP20 for rear terminals. L&T make, Cat No. EPLW110D	30.0000 NOS
15	Kit for Mounting MN 5 Relay on ML 4 / ML 6 contactor L&T make, Cat No. SS941520000	10.0000 NOS
16	HRC Fuse base with carrier Type: HC, 63A, 415V L&T make, Category no: SK91043 (both side cable) Suitable for L&T HF type Cylindrical fuse 2-63A	30.0000 NOS
17	Type: ML4 Power Contactor L&T make, Cat No. SS90910 Conformance Standards: IS/IEC 60947-4-1, IEC 60947-4-1 No. of poles: 3 Poles Motor duty 3Ø, 415V, 50 Hz Utilization category AC-3: 37/70 (kW/A) Coil Supply: 240V AC Auxiliary Contacts: 2 NO + 2 NC	8.0000 NOS

SL.No.	ITEM DESCRIPTION	QTY
18	High brightness and uniform LED Indication Lamp, Red colour Supply Voltage: 415VAC Bezel size:22.5 mm Type of LEDs: SMD LEDs Colour: Red Operating frequency:50 Hz Operating temperature: up to 65 degC Wire termination capacity: 2.5 sq.mm, 2 nos Operating life: 1,00,000 hours Low voltage glow protection: Yes Ingress protection: IP65 for front and IP20 for rear terminals. L&T make, Cat No. EPLR415A	10.0000 NOS
19	High brightness and uniform LED Indication Lamp, Yellow colour Supply Voltage: 415VAC Bezel size:22.5 mm Type of LEDs: SMD LEDs Colour: Red Operating frequency:50 Hz Operating temperature: up to 65 degC Wire termination capacity: 2.5 sq.mm, 2 nos Operating life: 1,00,000 hours Low voltage glow protection: Yes Ingress protection: IP65 for front and IP20 for rear terminals. L&T make, Cat No. EPLY415A	10.0000 NOS
20	High brightness and uniform LED Indication Lamp, Blue colour Supply Voltage: 415VAC Bezel size:22.5 mm Type of LEDs: SMD LEDs Colour: Red Operating frequency:50 Hz Operating temperature: up to 65 degC Wire termination capacity: 2.5 sq.mm, 2 nos Operating life: 1,00,000 hours Low voltage glow protection: Yes Ingress protection: IP65 for front and IP20 for rear terminals. L&T make, Cat No. EPLB415A	10.0000 NOS

GENERAL TERMS AND CONDITIONS FOR E BID SUBMISSION

Please submit your e-bids conforming to the specifications and the terms and conditions attached as per instructions given below:

1. MAKE: L&T ELECTRICAL AND AUTOMATION
2. PRODUCT CATALOG SHALL BE PROVIDED ALONG WITH THE BID DOCUMENT.
3. TEST CERTIFICATES TO BE PROVIDED ALONG WITH THE SUPPLY.
4. **This document should be filled, signed and submitted along with the offer. If any deviations you should mention it clearly.**
5. **ARBITRATION OF DISPUTES:** All disputes, differences, questions and claims arising out of, under or touching upon this Tender /Agreement/ Purchase Order/ Work Order shall be settled amicably between the parties through mutual discussion. If the parties fail to resolve the dispute by such mutual consultation within 21 days, then such disputes, difference, questions or claims shall be referred for resolution through arbitration by either of the parties to the India International Arbitration Centre or a Sole Arbitrator mutually agreed upon by the parties from a panel of arbitrators. The award of Arbitration shall be final and binding on the parties. The seat of the Arbitration shall be at Kochi, Kerala, India and the proceedings of the arbitration shall be held at Kochi, Kerala, India in accordance with the India International Arbitration Centre Act 2019 / Indian Arbitration & Conciliation Act 1996 or any statutory modification or re-enactment thereof for the time being in force.
When the contract is with foreign vendor, the vendor has the option to choose arbitration in accordance with the provisions of The India International Arbitration Centre Act 2019 / The Indian Arbitration and Conciliation Act, 1996 / UNCITRAL (United Nations Commission on International Trade Law Arbitration) Arbitration Rules."
6. The bid shall contain as integral part of the same the following compliance statement: "We have read, understood and accepted the terms and conditions of purchase and related documents forming part of this enquiry and agree to supply the goods in compliance with the same."
7. Bidders should carefully study the documents of this enquiry. All terms and conditions set out there in the enquiry shall be binding on the bidders unless conflicting with any terms and conditions expressly stated by HOCL while accepting any bid, in the event of such acceptance.
8. Bids shall be valid for a minimum of 60 days from the due date for receipt and opening of the bids.

9. Specification of the Product: Specifications offered product shall be uploaded along with technical bid.
10. Payment terms shall be: GeM standard Payment terms - within 10 days.
11. Tenderer should agree for inspection of material at their site, if desired by HOCL. The inspection may be carried out by the representative of HOCL or by a third party or jointly.
12. The Tenderer must specify their GSTIN No & HSN code of material offered in the BID.
13. The successful tenderer shall, if so desired by HOCL, deposit an amount equivalent to 5% of the value of order as security deposit within 21 days of the order towards satisfactory execution of the order. No interest will be paid on this amount by HOCL.
14. Delivery will be as per delivery schedule given by HOCL in the BOQ.
15. Manufacturers test certificate in original or attested, guarantee certificates in original, drawings in original etc. as applicable shall be provided along with the supply.
16. Tenderer may attach necessary catalogues/drawings/detailed specifications of the items wherever required. Also clearly specify the make/model of the item offered.
17. Purchase preferences, EMD/SD Exemption etc for PSUs/SSI units etc will be applicable as per GOI directives from time to time. For this, the tenderer should claim their eligibility along with the supporting documents in their offer itself.
18. Restriction on procurement from Bidder who shares the land border with India
 - a. Any bidder from a country which shares a land border with India will be eligible to bid, only if the bidder is registered with the Department for promotion of Industry and Internal Trade (DPIIT). (Pl. refer office Memorandum no. 6/18/2019-PPD dated 23rd July 2020) Such bidders should submit the valid copy of registration certificate along with tender. However the said requirement of registration will not be applicable to bidders from those country to which Govt. of India has extended lines of credit or in which Govt. of India is engaged in development of projects. Bidders may appraise themselves of the updated lists of such countries available in the website of Ministry of External Affairs.
 - b. **All Bidders shall furnish compliance certificate with respect to above clause as per the format in Annexure-V along with the bid.**
19. The GeM standard term for delivery, payment and price is as follows:

- i. GeM Std. Payment terms: 100% payment will be released within 10 days of issue of consignee receipt-cum-acceptance certificate (CRAC) and submission of bills.
- ii. Delivery: Free Delivery at Site basis including loading/unloading.
- iii. Price: Quoted price is all inclusive (i.e., freight, taxes and duties etc.)

Pls. note that no deviation is allowed in the above terms, So please ensure that the rate quoted against GeM tender is all inclusive value i.e inclusive of all taxes and duties and on delivered basis and also the payment term shall be within 10 days from the date of receipt & acceptance of material at site.

ANNEXURE-II

ELIGIBILITY CRITERIA FOR PARTICIPATING IN THE BID

OFFERS OF BIDDERS WHO SATISFY THE FOLLOWING ELIGIBILITY CRITERIA ONLY WILL BE CONSIDERED

- a) Vendor should submit Balance sheet of last 3 financial Years.
- b) Vendor should have upload work order copies of Minimum 3 Nos. of Reputed Customers preferably PSUs/Govt. Organizations for similar items.
- c) Repeat works order copies or satisfactory performance certificates issued by reputed organizations preferably PSUs for similar items.
- d) Client list.

Vendor should provide documentary evidences for all the above along with the Technical Bid. HOCL registered vendors are exempted from furnishing above document as in point nos. a to d.

ANNEXURE III-A**COMMERCIAL TERM FORMAT**

(Please fill up the details mentioned below in your letter head and upload along with your bid)

FOR OFFERS THROUGH GEM PORTAL (AS PER GEM STANDARD TERMS AND CONDITIONS ONLY, NO DEVIATION WILL BE ALLOWED)

PAYMENT TERM IS WITHIN 10 DAYS OF RECEIPT AND ACCEPTANCE OF MATERIAL AT SITE

RATE QUOTED SHOULD BE INCLUSIVE OF GST AND FREIGHT CHARGES TO DELIVER THE MATERIAL AT SITE

Sl. No.	DETAILS REQUIRED	
1	Name and Address of Organization	
2	Phone No.	
3	GSTIN	
4	E-mail id for correspondence	
5	Contact Person Name and Mobile No.	
6	Whether registered with MSME/NSIC (If so pl. enclose documentary proof):	
7	Validity of offer	
8	Delivery period	
9	Certificates provided along with supply, if any	
10	Deviation in specification, if any	

I/We here by confirm that, I/We have not been blacklisted in the past by any Public Sector Undertakings/ Government organizations.

Signature and Stamp

ANNEXURE III-B**(KINDLY FILL THIS SHEET AND SUBMIT IN -COMMERCIAL/TECHNICAL BID)**

Name of Bidder:		
Sl. No.	Commercial Clauses	Bidder Confirmation (Please put <input checked="" type="checkbox"/> in front of your confirmation)
1	Whether bidder (a proprietary concern, Partnership Firm, Company) is currently on holiday list/black list/de-listed or has been put on holiday/blacklisted/de-listed at any PSU/govt. Organization. If so, give details.	<input type="checkbox"/> Yes, We are on holiday List/Black List/De-List <input type="checkbox"/> No
2i	Whether the party is registered under Micro/Small/Medium Enterprises act 2006 (Please furnish the proof)	<input type="checkbox"/> Micro <input type="checkbox"/> Medium <input type="checkbox"/> Small <input type="checkbox"/> No
2ii	Status of MSE Bidder	<input type="checkbox"/> Manufacturer <input type="checkbox"/> Services <input type="checkbox"/> Not Applicable
2iii	Whether MSE bidder is offering product manufactured by him/her	<input type="checkbox"/> Yes <input type="checkbox"/> No
3i	All MSE bidders shall register / declare their UAM Number on CPP Portal and copy of this registration / declaration shall be attached with the offer; failing which such bidders will not be able to enjoy benefits as per PP Policy for MSME order, 2012. <u>SSI/MSME/NSIC/UAM/DIC registration certificate</u>	<input type="checkbox"/> Mention UAM Number <input type="checkbox"/> Not Applicable
3ii	Submitted valid document against clause no 3i	<input type="checkbox"/> Submitted <input type="checkbox"/> Not Applicable
4i	Whether the proprietor of "MSME" enterprise is from SC/ST category (Please attach caste certificate issued by competent authority)	<input type="checkbox"/> Yes <input type="checkbox"/> No
4ii	Whether the proprietor of "MSME" enterprise is woman (i.e. Woman proprietorship, or holding minimum 51% shares in case of Partnership/Private Limited Companies)	<input type="checkbox"/> Yes <input type="checkbox"/> No
4iii	Submitted certificate against clause no 4ii	<input type="checkbox"/> Submitted <input type="checkbox"/> Not Applicable
5	AGREED TO ALL TERMS AND CONDITIONS OF ENQUIRY: It is hereby stated that the quotation/offer submitted is in full compliance with the documents issued against the enquiry and also further confirmed that there is no deviation from all the terms and conditions as per the enquiry. Non-acceptance or deviation to HOCL's standard terms and conditions mentioned in enquiry documents may lead to rejection of offer, no correspondence shall be done for clarifications	<input type="checkbox"/> Agreed <input type="checkbox"/> Not Agreed
DATE :		
SIGN AND STAMP OF BIDDER		

ANNEXURE-IV

BID SECURITY DECLARATION

ANNEXURE TO BE SUBMITTED ALONG WITH THE BID AGAINST TENDER
NO _____

I/We.....hereby declare
that:

1. I will not revoke the tender within the stipulated period/ validity period OR increase the quoted rates.
2. I will commence the work on receipt of Purchase Order.
3. I will not withdraw or amend the tender or impair or derogate from the tender in any respect within the period of validity of the tender.
4. I will furnish the required performance security within the specified period.

NAME AND ADDRESS OF THE BIDDER

PLACE :

DATE :

SIGNATURE AND STAMP OF THE BIDDER

ANNEXURE-V

COMPLIANCE TO CLAUSE W.R.T MANADATORY REGISTRATION OF VENDORS FROM COUNTRIES SHARING LAND BORDER WITH INDIA, WITH DPIIT

Date: _____

TO WHOMSOEVER IT MAY CONCERNS

"I have read The clause titled restrictions on procurement from a bidder of a country which shares a land border with India.

I certify that M/s.....(Name Bidder) is not from such a country

Or

I hereby certify that M/s.(name of Bidder) is from a country which shares land border with India and fulfills all requirements in this regard and is eligible to be considered. Enclosed herewith Valid Registration Certificate

Or

I hereby certify that M/s..... (Name of Bidder) is from such a country which shares land border with India, however the said requirement of registration will not be applicable to bidders as Govt. of India has extended lines of credit or in which Govt. of India is engaged in development of projects. Enclosed herewith documentary evidence in this regards

We confirm that if it is established that we have provided any false information in pursuance to above clause, while competing for this contract then our Bid shall be rejected.

We further confirms that, if it is established that we have not complied with terms of aforesaid clause, during execution of contract, this would be a sufficient ground for immediate termination of the contract as per tender provision and shall be dealt accordingly

Name of the Bidder

Stamp & Signature of the Bidder